

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 2440-1321:101

Page 1 of 1

CATEGORY: Insulation

LISTEE: SWD Urethane, 222 S. Date Street, Mesa, AZ 85210
Contact: Ron Whipple (602) 969-8413

DESIGN: SWD 115, 250, 450 and 451, 2-component (A&B) spray-applied foamed plastic insulation. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:	PRODUCT	DENSITY (LB/CU FT)	THICKNESS (INCHES)	FLAME SPREAD	SMOKE DEV
	SWD115	1.9	1	50	200
	SWD250	1.9	1	25	250
	SWD450	2.0	2	20	250-300
	SWD450	2.0	6	25	350-450
	SWD451	2.0	2	20	250-300
	SWD451	2.0	6	25	350-400

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listees name, product label and UL label.

APPROVAL: Listed as insulation for use in stud wall space of combustible construction when the interior room space is protected by an approved thermal barrier providing a 15-minute finish rating when tested to specified building standards. May be used in attic and crawl spaces of combustible construction limited to entry for service of utilities when separated from all open space as required by applicable building standards.

02-08-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 21, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager